



CITY OF

PORTLAND, OREGON

DEPARTMENT OF PUBLIC WORKS

Mike Lindberg, Commissioner

November 2, 1981

Chapman Chemical Co.
10505 N. Macrum Avenue
Portland, Oregon 97203

Attn: Doug Carmon, Superintendent

Gentlemen:

As stated in my conversation with Chuck Pear McCadden's and my visit to your plant on 10/ by Jim McCadden during his telephone convers on 10/27/81, this office is extremely concer status of Chapman's industrial wastewater pr We wish to point out that the pretreatment and discharge procedures approved earlier (see your Waste Analysis Report of 2/16/81) may not be modified without prior approval from this office. This means that you must request in writing at least 30 days in advance of the effective date of the proposed modifications stating (1) the reasons for the request, and (2) the technical procedures (including adequate plans and specifications) to be employed.

Since the current situation is understood to be of short term and can be permanently corrected with just one or two more non-standard discharge procedures, this office will allow Chapman to discharge from the temporary holding tank located above-grade inside the processing plant. This permission is given with the following conditions:

1. Chapman Chemical Co. will discharge the treated effluent to the City sewer only during normal working hours on a week day.
2. Chapman will give this office at least 48 hours notice.

PS Form 3811, Nov. 1976

● SENDER: Complete items 1, 2, and 3. Add your address in the "RETURN TO" space on reverse.

1. The following service is requested (check one).
☐ Show to whom and date delivered 25¢
☐ Show to whom, date, & address of delivery 45¢
☐ RESTRICTED DELIVERY.
Show to whom and date delivered 85¢
☐ RESTRICTED DELIVERY.
Show to whom, date, and address of delivery \$1.05
(Fees shown are in addition to postage charges and other fees).

2. ARTICLE ADDRESSED TO:
Chapman Chemical
Doug Carmon

3. ARTICLE DESCRIPTION:
REGISTERED NO. CERTIFIED NO. INSURED NO.
594753

(Always obtain signature of addressee or agent)

I have received the article described above.
SIGNATURE ☒ Addressee ☐ Authorized agent
John J. [Signature]

4. DATE OF DELIVERY
NOV - 5 1981

5. ADDRESS (Complete only if requested)

6. UNABLE TO DELIVER BECAUSE:

CLERK'S INITIALS

POSTMARK
PORTLAND, OREGON
NOV 5 1981

★ GPO : 1979 - O-207

USEPA SF



1495018

Chapman Chemical
November 2, 1981
Page 2

3. Chapman will sample and have an approved laboratory analyze the settled and skimmed wastewater for pH, oil and grease, and total phenol. A copy of the laboratory analysis shall be furnished to this office.
4. No discharge will begin until approved by this office.
5. A City representative shall be present during the direct pumpage from the overhead tank to the City manhole.
6. The final effluent shall meet the City Code in all respects.

If you have any questions regarding this letter, please don't hesitate to give me or Jim McCadden a call at 248-4678 or 248-4679.

Very truly yours,

BUREAU OF SANITARY ENGINEERING



H. G. Edmonds, P.E.
Senior Engineer

HGE:al

cc: W. A. Singleton, Director of Mfg., Chapman Chemical
Rich Glick, City Attorney's Office
Jim Cooke, Pollution Control Laboratory
Dan Brownson, Wastewater Management Div.